

Display hidden notes to specifier. (Don't know how? Click Here)

Copyright 2008 - 2010 ARCAT, Inc. - All rights reserved

## PART 1 GENERAL

#### 1.1 SECTION INCLUDES

A. Daylight Redirecting Film. (Micro-Replicated)

## 1.2 RELATED SECTIONS

- A. Section 08 54 13 Fiberglass Windows.
- B. Section 08 60 00 Roof Windows and Skylights.
- C. Section 08 83 13 Mirrored Glass Glazing.
- D. Section 08 44 23 Structural Sealant Glazed Curtain Wall.

#### 1.3 REFERENCES

- A. ASHRAE American Society for Heating, Refrigeration, and Air Conditioning Engineers; Handbook of Fundamentals.
- B. ASTM International (ASTM):
  - 1. ASTM D 882 Standard Test Method for Tensile Properties of Thin Plastic Sheeting.
  - 2. ASTM D 412 Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers -- Tension.
  - 3. ASTM D 624 Standard Test Method for Tear Strength of Conventional Vulcanized Rubber and Thermoplastic Elastomers
  - 4. ASTM D 1004 Standard Test Method for Tear Resistance (Graves Tear) of Plastic Film and Sheeting.
  - 5. ASTM D 1044 Standard Method of Test for Resistance of Transparent Plastics to Surface Abrasion (Taber Abrader Test).
  - 6. ASTM D 2240 Standard Method for Rubber Property Durometer Hardness.
  - 7. ASTM D 2582 Standard Test Method for Puncture-Propagation Tear Resistance of Plastic Film and Thin Sheeting.
  - 8. ASTM D 5895 Standard Test Methods for Evaluating Drying or Curing During Film Formation of Organic Coatings Using Mechanical Recorders.
  - 9. ASTM D 4830 Standard Test Methods for Characterizing Thermoplastic Fabrics Used in Roofing and Waterproofing.
  - 10. ASTM E 84 Standard Method of Test for Surface Burning Characteristics of Building Materials.
  - ASTM E 308 Standard Recommended Practice for Spectophotometry and Description of Color in CIE 1931 System.
  - 12. ASTM E 903 Standard Methods of Test for Solar Absorbance, Reflectance and

- Transmittance of Materials Using Integrating Spheres.
- 13. ASTM E 1886 Standard Test Method for Performance of Exterior Windows, Curtain Walls, Doors, and Impact Protective Systems Impacted by Missile(s) and Exposed to Cyclic Pressure Differentials.
- 14. ASTM E 1996 Standard Specification for Performance of Exterior Windows, Curtain Walls, Doors and Impact Protective Systems Impacted by Windborne Debris in Hurricanes.
- 15. ASTM F1642 Standard Method of Test for Glazing and Glazing Systems Subject to Airblast Loadings
- 16. ASTM F2912 Standard Specification for Glazing and Glazing Systems Subject to Airblast Loadings.
- 17. NFRC 100/200 (Formerly ASTM E903) Standard Methods of Test for Solar Absorbance, Reflectance and Transmittance of Materials Using Integrating Spheres.
- C. Window 6.3 A Computer Tool for Analyzing Window Thermal Performance; Lawrence Berkeley Laboratory.
- D. ANSI Z97.1 American National Standard for Safety Glazing Materials Used in Buildings Safety Performance Specifications and Methods of Test.
- E. IES LM-83-12: IES Spatial Daylight Autonomy (sDA) and Annual Sunlight Exposure.
- F. Consumer Products Safety Commission 16 CFR, Part 1201 Safety Standard for Architectural Glazing Materials.
- G. GSA-TS01 Standard Test for Glazing and Glazing Systems Subject to Airblast Loadings.
- H. ISO 16933, International Standard for Glass in Building: Explosion-resistant security glazing Test and classification for arena air-blast testing.
- I. Underwriters Laboratories Inc. (UL): UL 972 Burglary Resisting Glazing Material.

#### 1.4 PERFORMANCE REQUIREMENTS

- A. Fire Performance: Surface burning characteristics when tested in accordance ASTM E 84:
  - 1. Flame Spread: 25, maximum.
  - 2. Smoke Developed: 450, maximum.
- B. Product to redirect at least 80% of transmitted light upward at incident angle of 60 degrees.

#### 1.5 SUBMITTALS

- A. Submit under provisions of Section 01 30 00 Administrative Requirements.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
  - 1. Preparation instructions and recommendations.
  - 2. Storage and handling requirements and recommendations.
  - Installation methods.
- C. Verification Samples: For each film specified, two samples representing actual film color and pattern.

## 1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: All primary products specified in this section will be supplied by a single manufacturer with a minimum of ten year's experience.
  - 1. Provide documentation that the adhesive used on the specified films is a Pressure Sensitive Adhesive (PSA).

- B. Installer Qualifications: All products listed in this section are to be installed by a single installer with a minimum of five years demonstrated experience in installing products of the same type and scope as specified.
  - 1. Provide documentation that the installer is authorized by the Manufacturer to perform Work specified in this section.
  - 2. Provide a commercial building reference list of 5 properties where the installer has applied window film. This list will include the following information:
    - a. Name of building.
    - b. The name and telephone number of a management contact.
    - c. Type of glass.
    - d. Type of film.
    - e. Amount of film installed.
    - f. Date of completion.
- C. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
  - 1. Finish areas designated by Architect.
  - 2. Do not proceed with remaining work until workmanship, color, and sheen are approved by Architect.
  - 3. Refinish mock-up area as required to produce acceptable work.

#### 1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of hazardous materials, and materials contaminated by hazardous materials, in accordance with requirements of local authorities having jurisdiction.

## 1.8 PROJECT CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's recommended limits.

# PART 2 PRODUCTS

# 2.1 MANUFACTURERS

A. Acceptable Manufacturer: 3M Window Film , which is located at: 3M Center Bldg. 0235-02-S-27; St. Paul, MN 55144-1000; Toll Free Tel: 866-499-8857; Tel: 651-737-0196; Fax: 651-737-3446; Email:jdoberle@mmm.com; Web:www.3m.com/windowfilm

## 2.2 3M MICRO-REPLICATED DAYLIGHT DIRECTING FILM

## A. Physical Properties:

- 1. Composition: Polyester film with a translucent micro-replicated structure on one surface and pressure sensitive adhesive on the opposite side.
  - a. Film color: off-white, translucent.
  - b. Thickness: nominal 8.4 mils (0.21 mm).
- 2. Uniformity: No noticeable pin holes, streaks, thin spots, scratches, banding or other optical defects.
- 3. Identification: Labeled as to Manufacturer as listed in this Section.

## PART 3 EXECUTION

# 3.1 EXAMINATION

#### A. Film Examination:

- If preparation of glass surfaces is the responsibility of another installer, notify Architect in writing of deviations from manufacturer's recommended installation tolerances and conditions.
  - a. Glass surfaces receiving new film should first be examined to verify that they are free from defects and imperfections, which will affect the final appearance.
- 2. Do not proceed with installation until glass surfaces have been properly prepared and deviations from manufacturer's recommended tolerances are corrected. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result under the project conditions.
- 3. Commencement of installation constitutes acceptance of conditions.

#### 3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Refer to Manufacturer's installation instructions for methods of preparation for Impact Protection Adhesive or Impact Protection Profile film attachment systems.

## 3.3 INSTALLATION

- A. Daylight Redirection Film Installation:
  - 1. Install in accordance with manufacturer's instructions.
    - a. Film is intended for installation in clerestory windows, minimum 7 feet (2.13m) above finished floor space.
    - b. This film is directional it has a top and a bottom. Identify and mark the top of the film to ensure proper orientation.
  - 2. Pre-cut the film neatly and squarely to the proper height and width, approximately 1/4" (6 mm) shorter than the window opening prior to installation. Use a new blade tip after 3 to 4 cuts.
  - 3. Seal the left and right film edges with 3M 3950 Edge Sealer. Allow approximately 5-10 minutes for the edge sealer to dry.
  - Spray the slip solution, composed of one capful of baby shampoo or dishwashing liquid to 1 gallon of water, on window glass and adhesive to facilitate proper positioning of film.
  - Apply film to glass and spray film surface with slip solution. Squeegee from top to bottom of window with either horizontal or vertical strokes to ensure water is fully removed.
  - 6. Cut film edges neatly and squarely at a uniform distance of 1/8 inch (3 mm) from window sealant.
  - 7. Bump film edge with lint-free towel wrapped around edge of a 5-way tool, using a horizontal wiping motion.
  - 8. Upon completion of film application, allow 30 days for moisture from film installation to dry thoroughly, and to allow film to dry flat with no moisture dimples when viewed under normal viewing conditions.

# 3.4 CLEANING AND PROTECTION

A. Remove left over material and debris from Work area. Use necessary means to protect film before, during, and after installation.

- B. Touch-up, repair or replace damaged products before Substantial Completion.
- C. After application of film, wash film using common window cleaning solutions, including ammonia solutions, 30 days after application. Do not use abrasive type cleaning agents and bristle brushes to avoid scratching film. Use synthetic sponges or soft cloths.

**END OF SECTION**